

# ES Izjava o skladnosti

## *EC Declaration of Conformity*

**Iskra, d.d., Stegne 21, 1000 Ljubljana**

Proizvajalec (ime in naslov) / *Manufacturer (name and address)*

S polno odgovornostjo izjavljamo, da so naši proizvodi  
*We declare under our sole responsibility that our products*

**Rele za nadzor napetosti / *Monitoring voltage relay* MVR 33, MVR 41, MVR 43, MVR 43N, MVR 54, MVR 54N, MVR 55, MVR 55N, MVR 56, MVR 57 in /and MVR 57N**

Opis in tip / *Description and type*

skladni z zahtevami sledečih direktiv:  
*are in conformity with the provisions of the following regulations:*

**Direktiva o elektromagnetni združljivosti (EMC) 2004/108/ES**

**Nizkonapetostna direktiva (LVD) 2006/95/ES**

**RoHS direktiva 2011/65/EU**

*EC Directive on EMC 2004/108/EC*

*EC Directive on Low Voltage 2006/95/EC*

*EC Directive on RoHS 2011/65/EU*

Za preverjanje skladnosti so bili uporabljeni sledeči standardi:  
*The following standards were used for reference and to establish conformity:*

EN 60255-1:2010	Measuring relays and protection equipment - Part 1: Common requirements
EN 60255-5:2001	Electrical relays -- Part 5: Insulation coordination for measuring relays and protection equipment - Requirements and tests
EN 60255-27:2005	Measuring relays and protection equipment -- Part 27: Product safety requirements
EN 60255-26:2013	Measuring relays and protection equipment -- Part 26: Electromagnetic compatibility requirements

Ljubljana, 10. 02. 2015

Kraj in datum izdaje  
*Place and date of issue*

Jani Marinšek, Direktor kakovosti  
*Quality Director*

Ime in podpis odgovorne osebe  
*Name and signature of authorized person*

