

 **CERTIFICATE**  
**FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2600059

# Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)

**Type designation:** AFI2, AFI4

**Certificate holder:**  
ISKRA, d.o.o  
Stegne 21, SI-1000 Ljubljana,  
Slovenia

**The product complies with  
the standard(s):** EN 61008-1:2012+A1+A2+A11+A12  
EN 61008-2-1:1994 and A11

**Date of expiry:** 21 January, 2031

**EU Directive information:** The product listed has been evaluated by a Third Party Body and deemed to meet the listed harmonized standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification      **Place:** Kista - Stockholm

**Signed:**       **Date:** 21 January, 2026

Quan Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

## APPENDIX:

Reference No. SE-S-2600059

**Technical Data:**

Type designation	AFI2
Rated voltage (V)	110V~ or 240V~(230V~)
Rated current (A)	16, 25, 32, 40, 50, 63, 80, 100A
IP-Class	20
Frequency (Hz)	50/60
Poles No	2(1P+N)
Test Report	2601B0213SHA-001
Trademark	
Product information	IΔn= 0,01A(16, 25, 32, 40A), 0,03, 0,1, 0,3A, Type A and AC IΔc = Inc = 10kA
Type designation	AFI4
Rated voltage (V)	110V~ or 415V~(400V~)
Rated current (A)	16, 25, 32, 40, 50, 63, 80, 100A
IP-Class	20
Frequency (Hz)	50/60
Poles No	4(3P+N)
Test Report	2601B0213SHA-001
Trademark	
Product information	IΔn= 0,01A(16, 25A), 0,03, 0,1, 0,3A, Type A and AC IΔc = Inc = 10kA

**Manufacturing Sites:**

ID 98,414

ID 87,014

**Certification Body:**

Intertek Semko AB, Product Certification

**Place:** Kista - Stockholm

**Signed:**

**Date:** 21 January, 2026



Quan Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.