

 **CERTIFICATE**
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2600050

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCB0s)

Type designation: RFI1

Certificate holder:
ISKRA, d.o.o
Stegne 21, SI-1000 Ljubljana,
Slovenia

**The product complies with
the standard(s):** EN 61009-1:2012+A1+A2+A11+A12+A13

Date of expiry: 19 January, 2031

EU Directive information: The product listed has been evaluated by a Third Party Body and deemed to meet the listed harmonized standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.


Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:

Date: 19 January, 2026


Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

APPENDIX:

Reference No. SE-S-2600050

Technical Data:

Type designation	RFI1
Rated voltage (V)	110, 230/240V~
Rated current (A)	6, 10, 13, 16, 20, 25, 32, 40A
Rated Residual Operating Current (mA)	10, 30, 100, 300mA
IP-Class	20
Frequency (Hz)	50/60Hz
Poles No	1P+N, with switched neutral pole
Trademark	 Iskra ®
Test Report	2601B0208SHA-001
Product information	B- & C- type, type-A & -AC IΔm=6000A, Icn=Ics=4500, 6000A Energy limiting class 3 (only for 6kA) Bi-directional connection

Manufacturing Sites:

ID 98,414

ID 87,014

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 19 January, 2026

Anneli Averland Johansson

Intertek

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.